



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail: igp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2021-1404-08

Dated:- 08/3/2022

Subject: Fire NOC in favour of Druk Padma Karpo School Shay, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the instant school which has been done by I/C Fire and Emergency Services, Leh. The detailed report is as under:

Location / Accessibility:

The School building is constructed at Shay, Leh. It is located at Longitude 77.64444 and Latitude 34.074444. The Site is approximately 14 Kms away from Fire and Emergency Services Station Leh. It takes 20 minutes to reach the site which is approachable for fire appliances.

Detail of building:

The school building is having 6 blocks and a hostel, 4 courtyards with two blocks in each courtyard. Most part of school building is constructed of wood. The details of the block are as under:

1st block: It is single storied building having four office rooms. There is one window in each room and the size is 5x12 feet. All the windows have provision to open.

2nd block: It is two storied building having two stair cases. In the ground floor there are 6 class rooms. There is one window in each class room and the size is 5x12 feet. All the windows have provision to open. 1st floor have three class rooms.

3rd block: It is single storied building having 7 class rooms. There is one window in each room and the size is 5x12 feet. All the windows have provision to open.

4th block: It is single storied building having 4 class rooms. There is one window in each room and the size is 5x12 feet's. Two sides of the window have provision to open.

5th block: It is single storied building having 4 class rooms. There is one window in each class room and the size is 5x12 feet. All the windows have provision to open.

6th block: It is single storied building having 4 class rooms. There is one window in each class room and the size is 5x12 feet. All the windows have provision to open.

Hostel block:

Every court yard has two blocks and all the blocks are single storied building having 5 rooms. There is one window in each room and the size is 3x3 feet. Two sides of the window have provision to open.


Kitchen and Dining hall block:

It is single storied building having kitchen and dining hall. The size of dining hall is 144x28 sq. feet.

There are 878 students and 80 staffs.

The following Fire Safety equipment's found installed in School Building:


01. 48 no's of fire extinguishers ABC type 5 kg capacity found installed in the school building.


Druk Padma Karpo School
Shey, Leh UT Ladakh
Since 2001
OFFICE COORDINATOR





02. 06 no's of plastic water tanks 1000 litres capacity found appropriately placed at the overhead of the Hostel building
03. 12 no's of sand bucket found appropriately placed in the school building.
04. 60 thousand litres capacity underground water reserve in the school premises.
05. There are 04 no's of submersible bore connected with high rated pump found appropriately placed in the school premises.

FIRE NOC is given in favour of Druk Padma Karpo School Shay, Leh for a period of One year from the issuance of this letter provided the School management installs 2 no's of yard hydrant in a time of bound manner.


Director, F&ES, Ladakh
PHQ, Agaling, Leh

Copy to:

01. Principal, Druk Padma Karpo School Shay, Leh for info.
02. Superintendent of Police, F&ES, Ladakh for information and with the direction to DFO, F&ES, Leh for ensuring time bound installation of 2 no's of Yard hydrants in the school building in a time of bound manner.


Druk Padma Karpo School
Shey, Leh UT Ladakh

OFFICE COORDINATOR

