



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH

OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail: go-ladakh@police.ladakh.gov.in)

(Office Phone No: 01982-260888)

No: F&ES/Dir/NOC/2023- 7198-99

Dated: 23/04/2023

Subject: Fire NOC of Druk Padma Karpo School Shay, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the school which has been done by DFO Fire and Emergency Services, Leh. The detailed report is as under:

Location/ Accessibility:

The school building is constructed at Shay, Leh. It is located at Longitude 77.64444 and Latitude 34.074444. The Site is approximately 14 Kms away from Fire and Emergency Services Station Leh, it takes 20 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The school building is having 6 block and hostel, 4 courtyards with two blocks in each courtyard. Most part of school building is constructed of wood. The detail of the block is as under:

1st block: It is single stored building having four office rooms. There is one window in each room and the size is 5x12 feet. All the window has provision to open.

2nd block: It is two stored building having 9 two stair case. In the Ground floor there are 6 class rooms. There is one window in each class room and the size is 5x12 feet. All the window has provision to open. 1st floor has three class rooms.

3rd block: It is single stored building having 7 class rooms. There is one window in each room and the size is 5x12 feet. All the window has provision to open.

4th block: It is single stored building having 4 class rooms. There are one windows in each room and the size is 5x12 feet. Two side of the window have provision to open.

5th block: It is single stored building having 4 class rooms. There is one window in each class room and the size is 5x12 feet. All the windows have provision to open.

6th block: It is single stored building having 4 class rooms. There is one window in each class room and the size is 5x12 feet. All the windows have provision to open.

Hostel block:

Every court yard has two blocks and all the block is single storied building having 5 rooms. There is one window in each room and the size is 3x3 feet. Two side of the window have provision to open.


Kitchen and dining hall block:

It is single storied building having kitchen and dining hall. The size of dining hall is 144x28 sq. feet. There are 878 students and 80 staffs.

The following Fire Safety equipment's which are installed in School Building:


01. 48 number of fire extinguishers ABC type 5 kg capacity are installed in the school building.
02. 06 number of plastic water tank 1000 liters capacity overhead of the Hostel building
03. 12 number of sand bucket is installed in the school building.
04. 60 thousand liters capacity underground water reserve is in the school premises.
05. There are 04 number of submersible bores connected with high rated pump in the school premises.
06. Two-yard hydrant is installed in the premises of school building.

FIRE NOC is given in favour of Druk Padma Karpo School Shay, Leh for period of One year from the issuance.


Director, F&ES, Ladakh
PHQ, Agaling, Leh

Copy to:

01. Principal, Druk Padma Karpo School Shay, Leh for information and n/a.
02. Superintendent of Police, F&ES, Ladakh for information.
03. Office file.


OFFICE COORDINATOR

